

DISPATCH		CLASSIFICATION CONFIDENTIAL		PROCESSING ACTION	
TO	: Chief of Station, [REDACTED]	25X1A		MARKED FOR INDEXING	
INFO.	: Chief of Base, [REDACTED]	25X1A		NO INDEXING REQUIRED	
FROM	: Chief of Station, [REDACTED]	25X1A		ONLY QUALIFIED DESK CAN JUDGE INDEXING	
SUBJECT	: Additional Fire Protection for Communication and Operations Building, [REDACTED]			25X1A	MICROFILM
ACTION REQUIRED - REFERENCES See Below					
<p>1. A fire in subject building, which is of wood construction, could do considerable damage before available fire-fighting equipment could arrive. It is therefore recommended that two standpipes with hose racks be installed in the building.</p> <p>2. Attachment A shows recommended locations for hose racks. Both locations are near exterior doors for ready access, and, with seventy five feet of hose per rack, can provide coverage for the entire interior of the building at minimum expense.</p> <p>3. The existing water line to the building should provide sufficient water for effective use of either of the proposed stations. To provide sufficient water for their simultaneous use, the two-inch portion of line (ca 300 feet between hydrant and building) should be replaced by a four-inch line.</p> <p>4. The proposed interior fire lines may be run just below the ceiling and drop down to the fire valve, which, with the hose rack, should be mounted about five feet six inches from the floor. Each station should be equipped with seventy five feet of 1 1/2 inch linen hose, hose rack with supporting nipple, angle valve, hydrolator drain, couplings, and a nozzle with 1/4 or 3/8 inch diameter discharge. This equipment should be equal to Fire Hose Unit Type 234, Catalog No. 615U-ER-H of the Standard Fire Hose Company. It is recommended that one extra seventy-five foot length of hose with couplings be provided, for if either installed hose becomes wet, it must be taken out of service until completely dry.</p> <p>Attachment: Sketch</p> <p>Distribution: 25X1A Orig. & 1 - [REDACTED] w/att. 1 - [REDACTED] w/att.</p>					
CROSS REFERENCE TO 25X1A		DISPATCH SYMBOL AND NUMBER [REDACTED]		DATE 22 FEB 1966	
		CLASSIFICATION CONFIDENTIAL		17 February 1966	
		GROUP 1 Excluded from automatic downgrading and declassification		QS FILE NUMBER	
25X1A 1 - Registry wo/att. 25X1A ✓ [REDACTED] w/att.		ORIGINATING OFFICE [REDACTED] /A - TYPIST gb		EXT. 485	
		COORDINATING			
		OFFICE SYMBOL	DATE	OFFICER'S NAME	
		RELEASING			
		OFFICE SYMBOL DCO	DATE	OFFICER'S SIGNATURE [REDACTED] 25X1A	
(40)					